AMENDMEN'	Γ OF SOLICITAT	ION/MODIF	ICATION OF CONT	ΓRACT	1. C (ONTRACT ID COD	E	PAGE OF PAGES 1 c 3
2. AMENDMENT/MOI	DIFICATION	3. EFFECT	TIVE DATE	4. REQUISITION	ON/PU	RCHASE REQ.		CCT NO. (If
NO.		Aug	gust 22, 2000	NO.			applicable	·)
0004			,	SC	0600-00	0-0707		
6. ISSUED BY		7	SCO600	7. ADMINISTERED BY (If other than Item 6)				
DEFENSE ENERGY 8725 JOHN J. KINGM FT. BELVOIR, VA 2 BUYER/SYMBOL - M PHONE - (703) 767-	MAN ROAD, SUIT 2060-6222 F. MIKE WHITE/DESO	E 4950 AX - (703) 7	67-8757	CODE				
8. NAME AND ADDRI	ESS OF CONTRAC	CTOR (NO.,	street,city,county,Stat	e,and ZIP Code)		9a. AMENDMEN	T OF SOLIC	CITATION NO.
					X	S	P0600-00-R	-0048
						9b. DATED (SEE)	TEM 11)	
							March 31, 2	2000
						10a. MODIFICATI		ONTRACT/ORDER
						10b. 1	DATED (SEE	TITEM 13)
	11.	THIS ITEM	ONLY APPLIES TO	AMENDMENTS	OF SO	DLICITATIONS		
By completing Items 8 a copy of the offer submit FAILURE OF YOUR A OFFERS PRIOR TO TO to change an offer alread or letter makes reference	ted; or(c) By separa CKNOWLEDGME HE HOUR AND Da ly submitted, such o	ate letter or te CNT TO BE R ATE SPECIF change may b	elegram which include RECEIVED AT THE TED MAY RESULT e made by telegram o	es a reference to the PLACE DESIGNATION OF THE REJECTION OF The International Public Properties of the Public Properties of the International Public Public Properties of the International Public Pub	ne solic ATED I OF YO ach tel	itation and amendme FOR THE RECEIPT UR OFFER. If by v egram	of numbers. OF irtue of this a	amendment you desire
12. ACCOUNTING A	ND APPROPRIAT	TION DATA	(If required)					
			LIES ONLY TO MO HE CONTRACT/OR				S,	
	NGE ORDER IS IS	SUED PURSU	JANT TO: (Specify at				EM 14 ARE	MADE IN THE
	CT ORDER NO. IN VE NUMBERED CO		RDER IS MODIFIED	TO REFLECT TI	HE AD	MINISTRATIVE CH	ANGES (suc	h as changes in
			H IN ITEM 14, PUR				103(b).	
	PLEMENTAL AGR fy type of modifican		ENTERED INTO PU	JRSUANT TO AU	THOR	ITY OF:		
OTTLER (Speed	jy type of moutiteut	ion una aum	ortiyi					
E. IMPORTANT: Cont						s to the issuing office		
14. DESCRIPTION OF feasible.) Except as provided here			SEE THE FOL	LOWING PAGES	;		-	
and effect. 15A. NAME AND TIT	LE OF SIGNER (T	ype or print)				NTRACTING OFFI MOSER	CER	
		15C.DATE SIGNED			ES OF AMERICA			
	erson authorized to	sign)			ature o	of Contracting Officer	<u> </u>	

This amendment is issued to update Electric Utility Attachment J1 and Water Utility Attachment J2, which consist of adding additional inventory descriptions to Table 6 for each Attachment.

See the Attached.

A. J1, page J1-7, add the following inventory to Table 6:

TABLE 6New Secondary Meters
Electrical System Bolling AFB

Meter Location	Meter Description				
Building 523, Launderette	KWH				
Building 4514, Base Exchange	KWH – Replace existing inoperable meter				
Building 4447, Bolling Federal Credit Union	KWH- Replace existing inoperable meter				

B. <u>J2</u>, page J2-5, add the following inventory to Table 6:

TABLE 6New Secondary Meters
Water System Bolling AFB

Meter Location	Meter Description
Building 523, Launderette	To Read Gallons
Building 4570, Commissary	To Read Gallons
Building 4447, Bolling Federal Credit Union	To Read Gallons
Building 5, Fire Station	To Read Gallons
Building 1302, Blanchard Barracks, Navy	To Read Gallons
Building 10, Post Office	To Read Gallons
Building 50, Officers Club	To Read Gallons
Building 90, Marina Office	To Read Gallons
Building 928, MWR Equipment Rental	To Read Gallons
Building 1307, Community Center	To Read Gallons
Building 1310, Bowling Lanes	To Read Gallons
Building 2482, Slip Inn	To Read Gallons
Building 2565, NCO Club	To Read Gallons

The following information is provided in response to a question in reference to the Bolling AFB Request For Proposal. Information is not included as part of the amendment and does not alter in any way the terms and conditions of the solicitation.

Bolling AFB Utility Privatization Question and Answer

particularly in emergencies.

1. A detailed review of the Solicitation documents indicates that for most of the electric distribution system, the demarcation line between the equipment which the Contractor will own, and that which will remain in Bolling AFB ownership, is the secondary terminals of the transformers (which have 13.2 kV primaries). Note that there are several exceptions; these have secondary loops or underground conductors to either the building meter, or to the weatherhead for overhead lines. This constitutes an inconsistency and our question is whether the line of demarcation can be made to conform. To the extent possible, can the secondary terminals of the transformer be made the line of demarcation for all locations? In this manner, all lower voltage feeders would remain Bolling AFB property, and the 13.2 kV system (including transformers and switches) would become property of the Contractor. This clear demarcation will be very helpful to both parties,

The Governments requirement as currently specified by Demarcation Points and as currently delineated in the RFP document to include Utility Specific Attachments as well as the Right-of-Way, will remain as specified.